



JAMSHORO POWER COMPANY LIMITED (Genco-I)

No. CEOJ/R.E(M)/T-825/21/EE-II/ 5560

Dated: 02-6-2021

JPCL INVITING TENDER NOTICE

Subject: REPAIR & REHABILITATION WORKS OF 0.4KV MOTOR AND TRANSFORMER CONTROL SWITCHGEAR PANEL (SERIES-B) AT SUBSTATION DEMI PLANT UNIT NO.4, TPS, JAMSHORO (T-825/21/EE-II)

Tender on Lump Sum basis for the subjected work as detailed below are hereby invited from your firm on the terms and condition detailed below:-

S.N	Description	Unit	Qty
1	Repair & Rehabilitation work of 0.4KV Motor and transformer control distribution switchgear panel (Series-B) at Substation Demi Plant Unit No.4 TPS, Jamshoro	01 Panel Job (01 Panel consist 06 Nos. Breaker Trolley racks)	03
i)	Complete repairing, cleaning, finishing and proper wrapping insulation tape of main three phase copper bus bar Size 508 x 77 x 5 mm each		
ii)	Replacement of supporting china clay insulator of main 3-phase bus bar with new one size: 152 x 40 x 40mm (each panel 04pieces) as per sample		
iii)	Repairing and silver coating of bus bar in /out copper contact assembly 0.4KV current carrying capacity 300A Size: 101 x 30 x 6mm (each panel 18 pieces)		
iv)	Dismantling, cleaning and silver coating of control male/female copper contact strip of breaker and refilled (36 No. strips and each 6 points)		
v)	Cleaning, repairing and finishing of female copper 0.4KV contact of breaker trolleys (24 Nos. each panel)		
vi)	Replacement of all fused 220VAC ON/OFF breaker indicators with new one LED Based type and make connection (06 Nos.)		
vii)	Replacement of damaged front fiber connecting plate for 0.4KV MCCB Breaker Trolley with new one (03 Nos. each panel) Length: 260mm, Height 170mm, (Material Baculite Fiber, ABS imported Material (As per sample)		
viii)	Dismantling, repairing, chrome coating and reinstallation of door lock of front and back panel doors (10 Nos.)		
ix)	Checking, cleaning and repairing of MCCB breakers and magnetic contractor of 0.4 KV breaker trolley (03 Nos.) in each panel Replacement of faulty MCCB breaker and overloads of 0.4KV Breaker trolleys (01 No.)		
x)	Dismantling, repairing, finishing and powder coating color and then proper refitting of all switch gear panel and including 50 KV Transformers panel door both front and back sides		
xi)	Installation of bus bar voltage indication and 3-phase 380V LED for supply monitoring		
All jobs are carried out at site JPCL			

01. Last date of issuance of Tender is 16.06.2021 at 12:00 hrs. The tender will be received upto 17.06.2021, 14:30 hrs and open on same day at 15:00 hrs in presence of opening committee and bidders.

SPECIAL CONDITIONS:-

ELIGIBILITY OF CONTRACTORS

- 1- The Contractor/firm should be registered with Pakistan Engineering Council (PEC), in the field of Mechanical.
- 2- Firm having experience of same job & must attach documentary evidence. Without having experience no any firm's bid will consider.
- 3- The firm must be registered with FBR, having NTN active tax payer. Also registered with Sindh Revenue Board (SRB).

TENDER CAN BE PURCHASED

- 1) O/O Genco Holding Company Limited, Room No. 196-B, Wapda House, Lahore
- 2) O/O Chief Resident Representative, WAPDA 50-B-1, Block-6, P.E.C.H.S Near P.E.C.H.S Girls College Karachi
- 3) From this Office TPS, Jamshoro during office hours.

EARNEST MONEY (EACH TENDER) @ 3% of Total Bid Value in Favour of Resident Engineer(M) TPS, Jamshoro in Shape of CDR.



JAMSHORO POWER COMPANY LIMITED (Genco-I)

TENDER FEE (EACH
TENDER)

Rs. 1000/- only (Non-Refundable) or Rs.1250/- in the shape of Bank Draft (Non Refundable)

PLACE OF OPENING

O/O Chief Engineer/Tech. Director, Main Admn: Building, Thermal Power Station, Jamshoro.


NOTE:

The envelop containing the Tender shall be sealed & addressed to this office should be written following on the top face of the envelop

“ENQUIRY NO” “DUE FOR OPENING ON”

In case Government announces any public holiday or due to unavoidable circumstances, the tender will be opened on next working days.

JPCL reserve the rights to reject all bids or proposals at any time prior to the acceptance of a bid/proposal as per Rule-33 of the PPRA Rules.


Resident Engineer(Maint.)
JPCL, Jamshoro

C.c.to:

- 01) Chief Executive Officer, JPCL, Jamshoro.
- 02) Chief Engineer/Tech. Director, JPCL, Jamshoro.
- 03) Chief Financial Officer, JPCL, Jamshoro.
- 04) Electrical Engineer-II, TPS, Jamshoro.
- 05) PPRA Website www.ppra.org.pk, info@ppra.org.pk
- 06) JPCL website.